

# CSUB ASBESTOS SURVEY SUMMARY (1/01)

## Material

## Location

### **Building #1 - Classroom Building**

Exterior stucco	Entire building
12" gray floor tile & mastic	Halls
4'x2' ceiling panels	Classrooms, offices
Drywall mud / texturing	Entire building
Pipe & elbow insulation (3" - >10" O.D.)	Entire building

### **Building # 2 - Fine Arts**

Exterior stucco	Entire building
12" floor tile - w/ gray streaks	Entire building
Pipe & elbow insulation (3" - <10" O.D.)	Entire building
Brown baseboard	Entire building

### **Building # 3 – Lecture Building**

Drywall mud / texturing	Entire building
12" floor tile - white w/ gray spots	Entire building
12" floor tile & mastic - white w/ gray streaks	Entire building
Pipe, elbow & valve insulation	Mechanical room
Pipe & elbow insulation (3" - >10" O.D.)	Entire building
Exterior stucco	Entire building

### **Building # 4 - Performing Arts**

Drywall mud / texturing	Entire building
12" floor tile & mastic - white w/ gray streaks	Entire building
12" floor tile & mastic - brown w/ specks	Room 106
12" floor tile - white w/ tan specks	Room 106, hall & storage
Pipe, elbow & valve insulation	Mechanical room
Pipe & elbow insulation (3" - >10" O.D.)	Entire building
Exterior stucco	Entire building
12" floor tile – gray organically bound	Room 105
Mastic – black, soft	Room 105

### **Building # 5 – Administration East**

Drywall mud / texturing	Entire building
12" floor tile & mastic – tan	Entire building
Pipe, elbow & valve insulation	Mechanical room
Pipe & elbow insulation (3" - >10" O.D.)	Entire building
Exterior stucco	Entire building

### **Building # 6 - Faculty Towers**

Exterior stucco	Entire building
12" floor tile and mastic - white/gray	Entire building
Drywall mud / texturing	Entire building

**Building # 7 - Development & Public Affairs**

Drywall mud / texturing	Entire building
12" floor tile - white w/ gray spots	Entire building
12 " floor tile - gray w/ white streaks	Entire building
12" floor tile & mastic - white w/ gray streaks	Entire building
Pipe, elbow & valve insulation	Mechanical room
Pipe & elbow insulation (3" - >10" O.D.)	Entire building
Exterior stucco	Entire building

**Building # 8 - Academic Administration**

Drywall mud / texturing	Entire building
12" floor tile & mastic - white w/ gray streaks	Entire building
Pipe, elbow & valve insulation	Mechanical room
Pipe & elbow insulation (3" - >10" O.D.)	Entire building
Exterior stucco	Entire building

**Building # 9 – Administration**

Drywall mud / texturing	Entire building
12" floor tile & mastic - white w/ gray streaks	Entire building
Pipe, elbow & valve insulation	Mechanical room
Pipe & elbow insulation (3" - >10" O.D.)	Entire building
Exterior stucco	Entire building
4' lay in ceiling tile	Corridor north of kitchenette
Ceiling tile adhesive	President's office
Scratch finish & brown coat plaster	Entire building

**Building # 10 – Education / Student Services**

Roofing material & sealant	Entire roof, education only
Exterior stucco	Entire building

**Building # 11 - Central Plant**

Drywall mud / texturing	Entire building
12" floor tile & mastic - white w/ gray streaks	Entire building
Pipe, elbow & valve insulation (3" - >10" O.D.)	Entire building & mechanical rooms
Pipe & elbow insulation (3" - >10" O.D.)	Entire building
Gaskets	Boilers
Finish & brown coat plaster	East wall boiler room
Exterior stucco	Entire building
Scratch finish & brown coat plaster	Boiler room

**Building # 12 - Shower/Lockers**

Pipe & elbow insulation (3" - <10" O.D.)	Entire building
--	-----------------

**Building # 13 - Support Services**

4'x2' ceiling panels	Entire building
12" floor tile - beige streaked	Entire building
12" floor tile - light brown	Entire building
Drywall mud / texturing	Entire building

**CSUB Asbestos Survey Summary 1/01 - page 3**

**Material**

**Location**

**Building # 14 - Child Care Center**

Drywall mud / texturing (covered to at least 3')  
Roofing material  
12" floor tile - light brown (under carpet)

Offices, classrooms 1-2, playroom  
Roof A only - assumed positive  
Secretary's office, conference room

**Building # 23 - Dining Commons**

Pipe & elbow insulation (3" - <10" O.D.)  
Tank insulation

Entire building  
Entire building

**Buildings # 24-29 - Residence Halls**

Roofing material & sealant  
Pipe & elbow insulation (3" - <10" O.D.)  
Drywall mud / texturing

Roofs assumed positive, except building 25  
Mechanical rooms & restrooms  
Entire buildings

**Building # 30 - Science I**

Pipe & elbow insulation (3" - <10" O.D.)  
12" floor tile & mastic - gray  
12" floor tile & mastic - white w/ gray  
Roofing material  
Fire door core material  
Steam pipe insulation  
Hood cabinet insulating panel

Entire building & roof  
West wing  
East wing  
Entire roof, except levels E, F, & G  
Entire building  
Entire building  
Entire building

**Building # 36 - Science II**

Pipe & elbow insulation (3" - <10" O.D.)  
12" floor tile & mastic - gray  
12" floor tile & mastic - white w/ gray  
Roofing material  
Fire door core material  
Steam pipe insulation  
Hood cabinet insulating panel

Entire building & roof  
West wing  
East wing  
Entire roof, except levels E, F, & G  
Entire building  
Chemistry labs  
Entire building

**Building # 31 - Romberg Nursing Center**

12" floor tile & mastic - beige w/ specks  
Exterior stucco  
Roofing material & sealant  
Pipe & elbow insulation (3" - <10" O.D.)  
Ceiling tile mastic  
Decorative texturing  
Drywall joint compound  
Top set base mastic

Entire building  
Entire building  
Entire roof  
Entire building  
Entire building  
Entire building  
Entire building  
Entire building

**Building # 32 - Dorothy Donahoe Hall**

12" floor tile & mastic - tan  
12" floor tile & mastic - tan & gray  
12" floor tile - brown  
12" floor tile - gray  
12" floor tile - gray w/ light gray streaks  
Black baseboard & mastic  
Mastic under brown baseboard  
Duct insulation  
Top set base mastic

Entire building, except F100  
Entire building  
Entire building, except F100  
Entire building  
Entire building  
Entire building  
Entire building  
F-101  
Entire building

**CSUB Asbestos Survey Summary 1/01 - page 4**

**Material**

**Location**

**Building # 33 - Physical Education**

