

CSUB ASBESTOS SURVEY SUMMARY (1/02)

Material

Location

Building #1 - Classroom Building

Exterior stucco	Entire building
12" gray floor tile & mastic	Halls
4'x2' ceiling panels	Classrooms, offices
Drywall mud / texturing	Entire building
Pipe & elbow insulation (3" - >10" O.D.)	Entire building

Building # 2 - Fine Arts

Exterior stucco	Entire building
12" floor tile - w/ gray streaks	Entire building
Pipe & elbow insulation (3" - <10" O.D.)	Entire building
Brown baseboard	Entire building

Building # 3 – Lecture Building

Drywall mud / texturing	Entire building
12" floor tile - white w/ gray spots	Entire building
12" floor tile & mastic - white w/ gray streaks	Entire building
Pipe, elbow & valve insulation	Mechanical room
Pipe & elbow insulation (3" - >10" O.D.)	Entire building
Exterior stucco	Entire building

Building # 4 - Performing Arts

Drywall mud / texturing	Entire building
12" floor tile & mastic - white w/ gray streaks	Entire building
12" floor tile & mastic - brown w/ specks	Room 106
12" floor tile - white w/ tan specks	Room 106, hall & storage
Pipe, elbow & valve insulation	Mechanical room
Pipe & elbow insulation (3" - >10" O.D.)	Entire building
Exterior stucco	Entire building
12" floor tile – gray organically bound	Room 105
Mastic – black, soft	Room 105

Building # 5 – Administration East

Drywall mud / texturing	Entire building
12" floor tile & mastic – tan	Entire building
Pipe, elbow & valve insulation	Mechanical room
Pipe & elbow insulation (3" - >10" O.D.)	Entire building
Exterior stucco	Entire building

Building # 6 - Faculty Towers

Exterior stucco	Entire building
12" floor tile and mastic - white/gray	Entire building
Drywall mud / texturing	Entire building

Building # 7- Development & Public Affairs

Drywall mud / texturing	Entire building
12" floor tile - white w/ gray spots	Entire building
12 " floor tile - gray w/ white streaks	Entire building
12" floor tile & mastic - white w/ gray streaks	Entire building
Pipe, elbow & valve insulation	Mechanical room
Pipe & elbow insulation (3" - >10" O.D.)	Entire building
Exterior stucco	Entire building

Building # 8 - Academic Administration

Drywall mud / texturing	Entire building
12" floor tile & mastic - white w/ gray streaks	Entire building
Pipe, elbow & valve insulation	Mechanical room
Pipe & elbow insulation (3" - >10" O.D.)	Entire building
Exterior stucco	Entire building

Building # 9 – Administration

Drywall mud / texturing	Entire building
12" floor tile & mastic - white w/ gray streaks	Entire building
Pipe, elbow & valve insulation	Mechanical room
Pipe & elbow insulation (3" - >10" O.D.)	Entire building
Exterior stucco	Entire building
4' lay in ceiling tile	Corridor north of kitchenette
Ceiling tile adhesive	President's office
Scratch finish & brown coat plaster	Entire building

Building # 10 – Education / Student Services

Roofing material & sealant	Entire roof, education only
Exterior stucco	Entire building

Building # 11 - Central Plant

Drywall mud / texturing	Entire building
12" floor tile & mastic - white w/ gray streaks	Entire building
Pipe, elbow & valve insulation (3" - >10" O.D.)	Entire building & mechanical rooms
Pipe & elbow insulation (3" - >10" O.D.)	Entire building
Gaskets	Boilers
Finish & brown coat plaster	East wall boiler room
Exterior stucco	Entire building
Scratch finish & brown coat plaster	Boiler room

Building # 12 - Shower/Lockers

Pipe & elbow insulation (3" - <10" O.D.)	Entire building
--	-----------------

Building # 13 - Support Services

4'x2' ceiling panels	Entire building
12" floor tile - beige streaked	Entire building
12" floor tile - light brown	Entire building
Drywall mud / texturing	Entire building

CSUB Asbestos Survey Summary 1/01 - page 3**Material****Location****Building # 14 - Child Care Center**

Drywall mud / texturing (covered to at least 3')
Roofing material
12" floor tile - light brown (under carpet)

Offices, classrooms 1-2, playroom
Roof A only - assumed positive
Secretary's office, conference room

Building # 23 - Dining Commons

Pipe & elbow insulation (3" - <10" O.D.)
Tank insulation

Entire building
Entire building

Buildings # 24-29 - Residence Halls

Roofing material & sealant
Pipe & elbow insulation (3" - <10" O.D.)
Drywall mud / texturing

Roofs assumed positive, except building 25
Mechanical rooms & restrooms
Entire buildings

Building # 30 - Science I

Pipe & elbow insulation (3" - <10" O.D.)
12" floor tile & mastic - gray
12" floor tile & mastic - white w/ gray
Roofing material
Fire door core material
Steam pipe insulation
Hood cabinet insulating panel

Entire building & roof
West wing
East wing
Entire roof, except levels E, F, & G
Entire building
Entire building
Entire building

Building # 36 - Science II

Pipe & elbow insulation (3" - <10" O.D.)
12" floor tile & mastic - gray
12" floor tile & mastic - white w/ gray
Roofing material
Fire door core material
Steam pipe insulation
Hood cabinet insulating panel

Entire building & roof
West wing
East wing
Entire roof, except levels E, F, & G
Entire building
Chemistry labs
Entire building

Building # 31 - Romberg Nursing Center

12" floor tile & mastic - beige w/ specks
Exterior stucco
Roofing material & sealant
Pipe & elbow insulation (3" - <10" O.D.)
Ceiling tile mastic
Decorative texturing
Drywall joint compound
Top set base mastic

Entire building
Entire building
Entire roof
Entire building
Entire building
Entire building
Entire building
Entire building

Building # 32 - Dorothy Donahoe Hall

12" floor tile & mastic - tan
12" floor tile & mastic - tan & gray
12" floor tile - brown
12" floor tile - gray
12" floor tile - gray w/ light gray streaks
Black baseboard & mastic
Mastic under brown baseboard
Duct insulation
Top set base mastic

Entire building, except F100
Entire building
Entire building, except F100
Entire building
Entire building
Entire building
Entire building
F-101
Entire building

CSUB Asbestos Survey Summary 1/01 - page 4

Material

Location

Building # 33 - Physical Education

